

Exit Legends

MOTIVATION

Fire safety signs should comply with the requirements of the signs directive, unless being used to extend an existing installation. In these instances they may be the same format as those previously fitted if complying to BS 5499 Pt 1 (UK).

The viewing distance of any exit sign should be more than 200 times the height of the sign if internally illuminated or 100 times the height of the sign if externally illuminated.

COMPLIANCE

- BS2560**
Old style signs now obsolete and should be replaced



- BS5499: Pt. 1:1990:**
Interim format being reviewed. Not recommended for new installations



- Health & Safety (Signs & Signals) Regulations 1996**
European Signs Directive Format



TO SPECIFY

Specify the Exit Legend or plastic panel to be used with the emergency luminaire separately.



Exit Legends

ORDER CODES
FIRE SAFETY SIGNS

PRODUCT	MAN RUNNING LEFT	MAN RUNNING RIGHT	MAN RUNNING DOWN	MULTI MAN	LEGEND TYPE	MAX VIEWING DISTANCE
Sentry	SEN/L	SEN/R	SEN/D	SEN/ES	Low tack stick on	14m
Slice	CUT/L	CUT/R	CUT/D	–	Low tack stick on	22m
Weatherproof	EBU/LEED2	EBU/LEED1	EBU/LEER3	WBU/LKEE	Low tack stick on	22m
Exit	SEN/LPL	SEN/LPR	SEN/LPD	–	Plastic panel	36m
Egress Mini					Low tack stick on	22m
Egress Maxi	EBU/LEEL/2	EBU/LEEL/1	EBU/LEEL/3	WBU/LKEE	Low tack stick on	36m
Egress Double*					Low tack stick on	36m
Slot	LGNLPL	LGNLPR	LGNLPD	–	Plastic panel	36m
Legend	LGNLPL	LGNLPR	LGNLPD	–	Plastic panel	36m

* May require 2 legend panels