


Photometry

Cyra

RECESSED 600 x 600 SEMI SPECULAR LG3 CAT 2
1 x 40W TC-L Lamp



- SHR MAX = 1.831
- DLOR = 0.50



UTILISATION FACTORS UF(F)		SHR NOM=1.75									
Room Reflectance		Room Index									
C	W	F	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	N/A	0.43	0.46	0.47	0.50	0.51	0.52	0.53	0.54
0.50	0.30	0.20	N/A	0.40	0.42	0.44	0.47	0.48	0.49	0.51	0.51
0.00	0.00	0.00	N/A	0.37	0.39	0.41	0.43	0.44	0.45	0.46	0.47

CONVERSION TERMS


Lamp wattage	40W	55W
UF and PC	1.00	0.93

Cyra

RECESSED 600 x 600 SEMI SPECULAR LG3 CAT 2
2 x 40W TC-L Lamps



- SHR MAX = 1.67
- DLOR = 0.43



UTILISATION FACTORS UF(F)		SHR NOM=1.50									
Room Reflectance		Room Index									
C	W	F	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	0.31	0.35	0.37	0.39	0.42	0.43	0.44	0.46	0.46
0.50	0.30	0.20	0.28	0.32	0.34	0.36	0.39	0.40	0.41	0.43	0.44
0.00	0.00	0.00	0.25	0.29	0.31	0.33	0.35	0.37	0.38	0.39	0.40

CONVERSION TERMS


Lamp wattage	40W	55W
UF and PC	1.00	0.93

Softcell

RECESSED CAT 2/500 DIRECT/INDIRECT
1 x 55W TC-L Lamp



- SHR MAX = 1.66
- DLOR = 0.517



UTILISATION FACTORS UF(F)		SHR NOM=1.50									
Room Reflectance		Room Index									
C	W	F	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	0.40	0.44	0.47	0.49	0.51	0.53	0.54	0.55	0.56
0.50	0.30	0.20	0.37	0.41	0.44	0.46	0.48	0.50	0.51	0.52	0.53
0.00	0.00	0.00	0.34	0.38	0.40	0.42	0.44	0.46	0.47	0.48	0.49

CONVERSION TERMS


Lamp wattage	40W	55W
UF and PC	1.00	0.93

Softcell

RECESSED CAT 2/1000 DIRECT/INDIRECT
2 x 55W TC-L Lamps



- SHR MAX = 1.46
- DLOR = 0.367



UTILISATION FACTORS UF(F)		SHR NOM=1.25									
Room Reflectance		Room Index									
C	W	F	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	0.26	0.30	0.32	0.33	0.35	0.37	0.38	0.39	0.40
0.50	0.30	0.20	0.24	0.27	0.29	0.31	0.33	0.34	0.35	0.37	0.37
0.00	0.00	0.00	0.21	0.25	0.27	0.28	0.30	0.31	0.32	0.33	0.34

CONVERSION TERMS


Lamp wattage	40W	55W
UF and PC	1.00	0.93

Vespère

RECESSED 600 x 600 DIRECT/INDIRECT
1 x 40W TC-L Lamp



- SHR MAX = 1.684
- DLOR = 0.49



UTILISATION FACTORS UF(F)		SHR NOM=1.50									
Room Reflectance		Room Index									
C	W	F	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	0.28	0.32	0.36	0.38	0.42	0.44	0.46	0.48	0.50
0.50	0.30	0.20	0.24	0.28	0.31	0.34	0.38	0.40	0.42	0.45	0.46
0.00	0.00	0.00	0.20	0.24	0.27	0.30	0.33	0.35	0.37	0.40	0.41

CONVERSION TERMS


Lamp wattage	40W	55W
UF and PC	1.00	0.93

Vespère

RECESSED 600 x 600 DIRECT/INDIRECT
2 x 40W TC-L Lamps



- SHR MAX = 1.851
- DLOR = 0.51



UTILISATION FACTORS UF(F)		SHR NOM=1.75									
Room Reflectance		Room Index									
C	W	F	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	N/A	0.32	0.36	0.38	0.42	0.45	0.47	0.49	0.51
0.50	0.30	0.20	N/A	0.27	0.31	0.34	0.38	0.40	0.42	0.45	0.47
0.00	0.00	0.00	N/A	0.23	0.26	0.28	0.33	0.35	0.37	0.40	0.42

CONVERSION TERMS


Lamp wattage	40W	55W
UF and PC	1.00	0.93

Asymmetric Wallwasher

1 x 55W TC-L Compact Fluorescent Lamp



- DLOR = 0.535




Softlighter

RECESSED COMPACT LG3 CAT 2 LOUVRE
2 x 36W TC-L Lamps



- SHR MAX = 1.53
- DLOR = 0.531



UTILISATION FACTORS UF(F)		SHR NOM=1.50									
Room Reflectance		Room Index									
C	W	F	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	0.43	0.47	0.50	0.51	0.54	0.55	0.56	0.58	0.58
0.50	0.30	0.20	0.40	0.44	0.47	0.48	0.51	0.52	0.53	0.55	0.55
0.00	0.00	0.00	0.38	0.41	0.43	0.45	0.47	0.48	0.49	0.50	0.51

CONVERSION TERMS


Lamp wattage	24W	36W
UF and PC	0.98	1.00

Softlighter

RECESSED COMPACT LG3 CAT 2 LOUVRE
2 x 40W TC-L Lamps



- SHR MAX = 1.675
- DLOR = 0.537



UTILISATION FACTORS UF(F)		SHR NOM=1.50									
Room Reflectance		Room Index									
C	W	F	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	0.44	0.49	0.52	0.54	0.57	0.59	0.60	0.61	0.62
0.50	0.30	0.20	0.41	0.45	0.48	0.51	0.53	0.55	0.56	0.58	0.59
0.00	0.00	0.00	0.38	0.42	0.45	0.47	0.49	0.51	0.52	0.53	0.54

CONVERSION TERMS

Lamp wattage	40W	55W
UF and PC	1.00	0.93